

SSO Notification List

January 2009

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	1/2/2009	5700 Chinquapin Parkway	21239	Rags and Grease	Herring Run	0:20	1:00 PM - 1:20 PM	Gray Colored Water	40	Relieved Main line with Pressure Truck	Line turned over to be CCTV'ed	90455
2	1/3/2009	1100 Steelton Ave	21224	Rags, Trash and Grease	Herring Run	2:10	9:50 PM - 12:00 AM	Heavy Gray Water	1,300	Relieved main line choke with Pressure Truck	No Preventative Actions Reported	90518
3	1/3/2009	1800 W. Baltimore Street	21223	Rags, Trash and Grease	Gwynns Falls	3:00	7:00 PM - 10:00 PM	Heavy Gray Water	900	Relieved main line choke with Pressure Truck	No Preventative Actions Reported	90512
4	1/3/2009	3900 Harford Road	21218	Rags, Roots and Grease	Herring Run	2:00	11:40 Am - 1:40 PM	Heavy Gray Water	700	Relieved Manhole with hand tools and rodded choke	No Preventative Actions Reported	90504
5	1/5/2009	3001 Fallstaff Road	21209	Rags and Grease	Jones Falls	3:10	2:18 PM - 5:28 PM	Sewer Water and Paper	380	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	90594
6	1/5/2009	3001 S. Hanover Street	21225	Rags and Grease	Patapsco River	0:11	2:49 PM - 3:00 PM	Heavy Gray Water	275	Relieved ML Choke with Pressure Truck	No Preventative Actions Reported	90590
7	1/8/2009	601 W. Patapsco Ave	21225	Rags and Grease	Patapsco River	27:00	4:38 PM to 7:22 PM	Heavy Gray Water	4,860	Used by-pass pumping to stop overflow than used pressure truck to remove choke	No Preventative Actions Reported	90791
8	1/8/2009	1200 Joplin Street	21224	Grease	Patapsco River	0:50	12:40 PM - 1:30 PM	Gray Colored Water	150	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	90779
9	1/13/2009	1315 Ballard Way	21224	Rags & Grease	Patapsco River	1:40	5:20 PM - 7:00 PM	Water	Evidence of Overflow	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	91006
10	1/13/2009	1341 N. Carey Street	21217	Rags and Roots	Jones Falls	1:51	5:14 PM - 7:05 PM	Sewer Water, Paper Debris	Evidence of Overflow	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	91002
11	1/13/2009	2900 S. Hanover St	21225	Rags & Grease	Patapsco River	0:46	11:03 AM - 11:49 AM	Heavy Gray Water	230	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	90979
12	1/14/2009	2921 Stranden Road	21230	Rags	Gwynns Falls	2:25	2:20 PM - 5:45 PM	Sewer Water	290	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	91063

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
13	1/16/2009	1923 McCulloh Street	21217	Rags	Gwynns Falls	1:19	12:41 PM - 2:00 PM	Heavy Gray Water	Evidence of Overflow	Relieved ML Choke w/ cutting machine	No Preventative Actions Reported	91153
14	1/19/2009	2027 Beechwood Avenue	21207	Rags, Trash and Grease	Gwynns Falls	1:55	10:30 AM - 12:25 PM	Gray Colored Water	575	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	91210
15	1/21/2009	3939 Roland Avenue	21211	Rags, Roots and Grease	Jones Falls	1:49	10:41 AM - 12:30 PM	Gray Colored Water	600	Relieved main line choke with Pressure Truck	Line turned over to be CCTV'ed	91278
16	1/21/2009	4800 Falls Road	21211	Rags, Roots and Grease	Jones Falls	2:00	12:00 PM - 2:00 PM	Heavy Gray Water	600	Relieved ML Choke with Pressure Truck	Line turned over to be CCTV'ed	91297
17	1/22/2009	1615 Sexton Street	21230	Rags and Grease	Gwynns Falls	4:47	5:43 PM - 10:30 PM	Sewer Water	Evidence of Overflow	Relieved ML Choke with Pressure Truck	Line turned over to be CCTV'ed	91377
18	1/23/2009	1200 Webster Street	21230	Rags and Grease	Inner Harbor	1:22	9:40 PM - 11:02 PM	Sewer Water	Evidence of Overflow	Relieved ML Choke w/ Pressure Truck	Line turned over to be CCTV'ed	91429
19	1/28/2009	2730 St. Paul Street	21218	Trash, Roots and Grease	Jones Falls	1:10	12:20 Pm - 1:30 PM	Gray Colored Water	Evidence of Overflow	Relieved House Connection choke w/ cutting machine	Line turned over to be CCTV'ed	91605
20	1/29/2009	907 Nottingham Road	21229	Rags, Roots and Grease	Gwynns Falls	4:00	2:00 PM - 6:00 PM	Heavy Gray Water	6,000	Relieved ML Choke w/ Pressure Truck	Line turned over to be CCTV'ed	91664
								TOTAL	16,900			